


PERFORMA REGARDING SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE

Date :04/01/2025

It is certified that an inspection team headed by Nagar Palika Parishad Pauri. Mr. Hemant Kumar inspected the **SGRR Public School Pauri** on 04/01/2025 and found that the **SGRR Public School Pauri** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of One Year.

Signature with seal. .....

Name

Designation

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 01/01/2025

It is certified that an inspection team headed by Mr. Hemant Kumar

(Name of Officers with designation) from Mr. Hemant Kumar Sanitary Inspector PHED

inspected the S.G.R.R. Public School, Pauri

(Name & Address of the school) on 01/01/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. JA 258/UTS/DLWOTM/S/2024-25 dated

of P.W. G. T. and M. L. V. S. Garhwal (PHED Lab) certified that the

S.G.R.R. Public School, Pauri (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 01/01/25 to 03/01/2026 (One year)

Signature with Seal:

Name : Hemant Kumar

Designation : Sanitary Inspector

Name & Address of the Office / Department : PHED Pauri

To
S.G.R.R. Public School
Pauri
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

M.C. Panchayat
Principal
Raj Public School
Pauri Garhwal
Att. No. 3530525
School Code- 21748

District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Agency Mohalla Near Pump House,
Srinagar Garhwal

Ph (O): 01346-252995, E-mail: ujl.ceepauri@gmail.com



TC-12709

Name and Address of Organization/Customer	Shri Guru Ram Rai publicschool, Vikash Marg, Pauri Garhwal.		
Test Report ID	258/UJS/DL.WQTMLS/2024-25	Reporting Date	03/01/2025
URL No.		Sample Location	Shri Guru Ram Rai publicschool, Vikash Marg, Pauri Garhwal.
Product Description	Drinking Water	Sample Collected by	Rahul Singh Negi
Reference Sample Identification:	DL.WQTM/ UJS/SG-01		
Date of start of Analysis:	01/01/2025		
Date of End of Analysis:	03/01/2025		
Date and Time of Sample Received:	01/01/2025, 10.30am		

TEST REPORT

SN	Parameters	Results	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source	Test Method
1.	Colour, Hazen, Max	1.0	5	15	IS 3025 (Part- 4)
2.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-05)
3.	pH at 25° C	7.08	6.5 to 8.5	No Relaxation	IS 3025 (Part-11)
4.	Turbidity, NTU, Max	Less than 0.5	1	5	IS 3025 (Part-10)
5.	Total Dissolved Solids (TDS) at 180° C, mg/L, Max	32.0	500	2000	IS 3025 (Part-16)
6.	Chloride, mg/L, Max	1.0	250	1000	IS 3025 (Part-32)
7.	Total Hardness (as CaCO ₃), mg/L, Max	22.0	200	600	IS 3025 (Part -21)
8.	Calcium (as Ca), mg/L, Max	5.6	75	200	IS 3025 (Part-40)
9.	Magnesium (as Mg), mg/L, Max	Less than 5.0	30	100	APIIA 24rd Ed.-3500-Mg Method B (By Calculation)
10.	Total Alkalinity (as CaCO ₃), mg/L, Max	18.0	200	600	IS 3025 (Part 23)

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Checked By

Review and Authorized By

(Er. Pooja D. Negi) 03/01/25
Authorized Signature Lab
District Level Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan, Srinagar



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Agency Mohalla Near Pump House,
Srinagar Garhwal
Ph (O): 01346-252995, E-mail: ujl.cepaury@gmail.com

Name and Address of Organization/Customer	Shri Guru Ram Rai publicschool, Vikash Marg, Pauri Garhwal.		
Test Report ID	258/UJS/DLWQTMLS/2024-25	Reporting Date	03/01/2025
		Sample Location	Shri Guru Ram Rai publicschool, Vikash Marg, Pauri Garhwal.
Product Description	Drinking Water	Sample Collected by	Rahul Singh Negi
Reference Sample Identification:	DLWQTML/UJS/SG-01		
Date of start of Analysis:	01/01/2025		
Date of End of Analysis:	03/01/2025		
Date and Time of Sample Received:	01/01/2025, 10.30am		

TEST REPORT

SN	Parameters	Results	Acceptable Limit As per (IS 0500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source	Test Method
1.	Residual Free Chlorine, mg/L, Max	Not Detected	0.2	1.0	APHA 24rd Ed.-4500-Cl-G
Bacteriological Parameters					
2.	Total Coliform, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B
3.	E. coli, MPN/ 100ml	Absent	Absent	Absent	APHA 23rd Ed.-9223-B


Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not to be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

**** End of Report****

Review and Authorized By


Checked By


(Er. Pooja Dikari)
Authorized Signatory, Lab
Authorized Signatory
District Level Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan, Srinagar